

## **ADDENDUM 3**

**PROJECT: 07-19-002 Fire Alarm Maintenance, Testing and Support RFP**

**BID / TIME DUE: ~~August 9, 2019 @ 1:00 P.M.~~ August 16, 2019 @ 1:00 P.M.**

### **QUESTIONS:**

1. Will WCC provide the lift necessary to complete the test and inspections? Or should the contractor assume responsibility for the lift cost?
  - a. **Contractor will need to provide a lift.**
2. Can you please define “after hours” for when WCC wishes the contractor to test and inspect the school? Also, in the RFP it states that testing will be done in blocks throughout the year: “The annual full system performance test will be performed during a scheduled break in class activities based on the colleges annual calendar. Buildings will be broken down according to size and will be performed on a quarterly or annual basis.” If the contractor is scheduled to test during breaks in scheduled activities, is after hours testing still going to be necessary? 9?
  - a. **Testing hours can be after 11pm. Work will be completed prior to 7am. The Contractor will provide sufficient manpower to accomplish the testing within a reasonable time determined by Waubonsee Community College.**
3. Can you provide the inspection reports for the missing buildings?
  - a. **These reports are unavailable. Additional drawings for these buildings have been posted to the Google Doc shared folder.**
4. Which wage classification do you want us to use for prevailing wage as fire testing is not listed in a prevailing wage category?
  - a. **Communication Technician**

**This addendum does not change the revised due date or time.**

**END OF DOCUMENT**

**Sugar Grove**

Rt. 47 at Waubonsee Drive  
Sugar Grove, IL 60554-9454  
(630) 466-7900

**Aurora Downtown**

18 S. River St.  
Aurora, IL 60506-4131  
(630) 801-7900

**Aurora Fox Valley**

2060 Ogden Ave.  
Aurora, IL 60504-7222  
(630) 585-7900

**Plano**

100 Waubonsee Drive  
Plano, IL 60545-2276  
(630) 552-7900